




DOMESTIC DRYER VENTING

2010 CMC 504.3.2.2



- 1. Domestic clothes dryer moisture exhaust ducts shall be of metal and have smooth interior surfaces.
- Listed clothes dryer transition ducts not more than 6-feet in length may be used in connection
 with domestic dryer exhausts. Flexible clothes dryer transition ducts shall not be concealed
 within the structure.

Details are not to scale.

3. Unless otherwise permitted or required by the dryer manufacturer's installation instructions and approved by the Authority Having Jurisdiction, domestic moisture exhaust ducts shall not exceed a total combined horizontal and vertical length of 14'-0", including two (2) 90 degree elbows. Two (2'-0") feet shall be deducted for each 90 degree elbow in excess of two (2).

In CMC 504.3.2.2